

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-0065:131 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** Faraday Inc, 805 South Maumee St., Tecumseh MI 49286  
Contact: Steve A. Blohm (517) 423-2111

**DESIGN:** Model 15222 and \*15222A fire alarm signal expanders. The unit is intended for use with a separately listed fire alarm control unit to provide additional signaling device current. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Primary: 120 VAC, 2A; and Secondary: 27.8 VDC nominal

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name or registered trademark "FOS", model number, electrical rating and UL label.

**APPROVAL:** Listed as control unit accessories when used in conjunction with separately listed, electrically compatible fire alarm control units and indicating devices. Not intended for use as a stand alone unit.

\*Rev. 11-09-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**MAY 15, 2001**

*Listing Expires **June 30, 2002***

Authorized By:

**BEN HO**, Supervising Deputy  
Program Manager